

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-10-07-30-05

**Product:** „EGGER laminate floor covering with antistatic modification class 32”

**Manufacturer:** Egger Retail Products GmbH & Co. KG  
Im Kissen 19  
59929 Brilon

**Order:** Classification of the electrostatic behaviour according to  
EN 14041:2008

**Test method:** Test of the body voltage according to EN 1815:1997

**Test report:** No. 270200/2 from 2010-07-30

**Test result:** The measured body voltage at 23 °C / 25 % humidity were  $\leq 2$  kV.  
The „EGGER laminate floor covering with antistatic modification class 32”  
fulfils the criterions for the classification as an  
**"Antistatic Floor Covering"**  
in accordance with the European Standard EN 14041:2008

Dresden, 30th July 2010



Head of laboratory



Engineer in charge